



## San Juan Unified School District

### *Facilities Business Department*

5320 Hemlock Street, Sacramento, California 95841

Telephone 916- 971-7283

Internet Web Site: [www.sanjuan.edu](http://www.sanjuan.edu)

Kent Kern, Superintendent of Schools

Frank Camarda, Assistant Superintendent, Operations, Facilities and Transportation

August 20, 2019

### **Addendum #1**

**Bid# 20-102**

**Sierra Oaks K-8 Fencing**

**Project #146-9716-19DM**

This Addendum modifies the original RFP documents as noted below. The attached documents supersede or augment the original information provided in the RFP where it adds to, deletes from, clarifies or otherwise modifies them. All other conditions and any previous addenda shall remain unchanged.

### **1 Bidder Questions and Answers:**

1) Q: After looking at plans and specs, I noticed that some details and specs are not typical of San Juan fence projects done in recent past. (ADA gates are over 4' wide and no place to install the closer, typical iron fence post detail is 12"x36" and at gates 18"x36" without rebar cage, mow strip is typical 12" wide)? Is chain link fence to have middle and bottom rail?

A: Answer for:

- Is chain link fence to have middle and bottom rail? Section 32 3113 – 3.02 I
- Closer for Ornamental fence material to match Chain link: Locinox USA – Mammoth 180 deg. Self-closing hinge kits, as found in chain link spec.
- without rebar cage? – Section 32 3119 - 3.02 D
- Gate/post size per drawings
- Mow strip shall be **12” wide** and depth per drawing

End of Addendum