

SAN JUAN UNIFIED SCHOOL DISTRICT



CCTV IP Camera Upgrade
SJUSD Project #392-9285-21DM

Sacramento County

ADDENDUM NO. 1

May 24, 2021

for

Bid Package # 21-128

Owner

**San Juan Unified School District
3738 Walnut Avenue
Carmichael, CA 95609**

Designer

**KMM Services, Inc.
5433 El Camino Ave., Suite 5
Carmichael, CA 95608**

This Addendum has been prepared to clarify, modify, delete, or add to the drawings and/or specifications for the above referenced project, and revisions to items listed here shall supersede description thereof prior to the above stated date. All conditions not specifically referenced here shall remain the same. It is the obligation of the Prime Contractor to make subcontractors, materials suppliers, etc. aware of any items herein that may affect submitted bids.

Acknowledge receipt of this addendum by inserting its number and date in the bidding documents. Failure to do so may subject bidder to disqualification.

All addenda items refer to the plans and specifications unless specifically noted otherwise. Any addenda items related to the Bid/Proposal must be used when submitting a bid. Non-use of these revised forms will constitute a bid being considered non-responsive.

PART A – BIDDING AND CONTRACT REQUIREMENTS

A1.01 Questions received:

QUESTIONS:	ANSWERS:
Q1) Are we allowed to intercept an existing data conduit at a jbox to get the camera cable to the IDF?	A1) Yes
Q2) Where required to match an interior paint color, does the school district have the paint codes or do we match as close as possible to the existing color?	A2) Match as close as possible.
Q3) Is the contractor supplying the SIP speaker?	A3) Yes.
Q4) On drawing T2.06 Camera 132 there is a sheet note 9 with no reference in the sheet note block.	A4) Sheet note #9 shall read "Not used".
Q5) Is the contractor supplying and installing any Patch Panels?	A5) Yes, contractor is to furnish patch panels as required.

San Juan Unified School District – KMM Services, Inc.

PART B – TECHNICAL REQUIREMENTS

N/A

PART C – DRAWINGS

N/A

END OF ADDENDUM No. 1